## Town of Port Deposit Water Treatment Plant 2008 Drinking Water Quality Report

PWSID: 007 0020



## Important Information about your Drinking Water:

## Special points of interest:

- The water at Port Deposit was tested for over 120 different compounds
- The Port Deposit
   Drinking water meets
   all State and Federal
   requirements
- Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some compounds. The presence of these compounds does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency (EPA) Safe Drinking Water Act Hotline (800-426-4791)

e're pleased to present to you the Annual Water Quality Report for 2008. This report is designed to inform you about the water quality and services we deliver to you every day. Maryland Environmental Service, an Agency of the State of Maryland, prepared this report on behalf of the Town of Port Deposit.

Our goal is to provide you with a safe and dependable supply of drinking water. More than 800 tests for over 120 compounds were conducted on the water at Port Deposit. We want you to understand the efforts made to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

We're pleased to report that your

drinking water meets all Federal and State requirements. This report shows the water quality and explains what it means.

If you have any questions about this

If you have any questions about this report or have questions concerning your water utility, please contact **Doug Dillon at (410) 378-4490.** 

The Water at Port Deposit won
First Place for Best
Tasting Surface Water
at the Annual MD Rural
Water Competition in
2002 through 2005!!

The water for Port Deposit comes from the Susquehanna River. After the water is pumped out of the river, we settle and filter the water, add disinfectant to protect against microbial contaminants and adjust the pH of the water to protect against corrosion. The Maryland Department of the Environment completed an assessment of the source water; Copies are available upon request.

Public Meeting Information: For the opportunity to ask more questions or participate in decisions that may affect your drinking water quality, a public meeting is held the First Tuesday, each month at 7:30 pm at the Town Hall.

ome people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791). And the second of the control of the second of the second

Page 2

Town of Port Deposit Water Treatment Plant 2008 Drinking Water Quality Report

## **Water Quality Data**

The table below lists all the regulated drinking water contaminants that we detected during the past several years. The presence of these compounds in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data

presented in the table is from testing done January 1 - December 31, 2008. The State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year.

Port Deposit Treated Water Q	uanty Report 2008			<u> </u>
Definitions				
Maximum Contaminant	The highest level of a contaminant that is allowed in drinking water. MCL's are set			
Level (MCL)	as close to the MCLU's as leasible using the hest available treatment technology			
Maximum Contaminant	The level of a contaminant in drinking water below which there is no known or			
Level Goal (MCLG)	expected hak to hear	th. MCLGs allow for	a margin of safety	
Treatment Technique (TT)	A required process in	tended to reduce the	level of a contamir	ant in drinking water
Previous III				water
NTU = Nephelometric Turbidity Units				
pCi/l = picocuries per liter (a measure o	of radiation)		**************************************	
mrem/yr = millirem per year (a measure	of radiation absorbed by t	he body)	· ·	
pun = parts per million or milligrams pe	r liter			
ppb = parts per billion or micrograms pe				
Contaminant	Highest Level	Highest Level	Ideal Goal	Typical
	Allowed	Detected	(EPA's MCLG)	Sources of
	(EPA's MCL)		(	
Regulated at the Treatment Plant				Contaminant
Gross Alpha (2007 Testing)	15 pCi/l	1 pCi/1	() p Ci/l	Fracion of natural 1
Gross Beta (2007 Testing)	4 mrem/yr	0.24 mrem/yr	0 rarem/yr	Frosion of natural deposits
Combine Radium (2007 Testing)	5 pCi/l	0.1 pCi/l	C pCi/l	Decay of natural deposits
Di (2-ethylhexyl) phthalate	бррь	0.5 ppb	Oppb	Erosion of natural deposits PVC Plastics
Vitrate	10 ppm	1.11 ppm	10 ppm	Runoff from fertilizer use
Nickel	0.1 ppm	0.02 ppm	0.1 ppm	Exercise of a street like
fluoride	4 ppm	1.24 ppm	4 ppm	Erosion of natural deposits
Barium	2 ppm	0.046 ppm	2 ppm	Erosion of natural deposits
legulated in the distribution system			z P.bitt	Erosion of natural deposits
otal Trihalomethanes (TTHM)	80 ppb	Range from	n/a	December 6 1
Taloacetic Acids (HAA5)	60 ppb	7.61 to 32.28 ppb	n/a	By-product of drinking water
		Range from		disinfection
		8.03 to 33.06 ppb		By-product of drinking water
egulated at the Consumer's Tap			——————————————————————————————————————	disinfection
opper	1.3 ppm (action level)	90th percentile =	12	
005 Testing)		0.089 ppm	1.3 ppm	Corrosion of household plumbing
ead	15 ppb (action level)	90th percentile =	0 ==-1	fixtures and systems
005 Testing)		7 ppb	0 ppb	Corrosion of household plumbing
ested at the treatment plant		, 660		fixures and systems
urbidity	TT 611			
	TT=filtration	0.60 NTU	r/a	Soil Runoff
arbidity cannot exceed 1.0 NTU and May 2008, two (2) of the 109 turbi	d must be $< or = to 0.3 N$	ITU in at least 95%	of the measurer	
May 2008, two (2) of the 109 turbi	dity results were over 0	NITTI Total	i.	that i each month.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and can pick up substances resulting from the presence of animals or from human activity.

n order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain compounds in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in Fottled water which must provide the same protection for public health.